

Includes:

- Warehousing and storage
- Shipping and receiving



Warehouse Occupancies

The B.C. Fire Code requires building owners and occupants to comply with the requirements on this checklist and in the Fire Safety & You brochure.

CHECKLIST: COMMON FIRE SERVICE REQUIREMENTS

- **Address:** must be visible from road and lane, free from foliage, trees, etc. and in a contrasting colour.
- **Electrical equipment:** must be free of dust, with clearance from combustibles.
- **Emergency lighting:** may be provided by battery packs with remote and attached heads, or by emergency generators that will illuminate specified A/C fixtures or remote light heads. Must be operational, with no visible damage, and serviced and tagged annually by a certified technician.
- **Exit doors:** must not be locked or blocked from either the inside or outside. Must be unlocked from the inside when the building is occupied.
- **Exit signs:** must be visible and remain illuminated at all times when building is occupied.
- **Exposures such as pallets or flammable items:** should be noted as to location and type.
- **Fire alarm systems:** must have a working A/C power-on bulb and be in good working condition with no audible or visual damage. Must have a current service tag (within the last 12 months) and up-to-date logbook.
- **Fire doors:** must not be blocked or wedged open, including stairwell doors. No door wedges to be used.
- **Fire hose cabinets:** there must be clear access to cabinets and the hose must be in good repair and complete with nozzles.
- **Fire hydrants:** must be accessible, free of damage and serviced within the specified date. Private hydrants require annual service, with records kept on site.
- **Fire lanes:** must have an adequate clear width of six unobstructed metres.
- **Fire separations:** must have no holes or openings that compromise their purpose.
- **Forklifts:** propane and gasoline-fired forklifts require a minimum rating 2A-10BC.
- **Garbage disposal:** commercial containers must be located six metres from combustible buildings, and if inside, should have tight-fitting lids and be in fire-separated rooms.
- **'No smoking' signs:** must be posted in hazardous areas.
- **Portable fire extinguishers:** must:
 - be located adjacent to corridors or aisles that provide access to exits.
 - be mounted in a visible location, accessible, and serviced and tagged at least once per year by a certified technician.
 - be full and functioning (no leaks, damage, corrosion, broken parts or clogged nozzles).
 - have a minimum rating 2A-10BC.
- **Portable heaters:** must be an approved type and kept away from combustibles.
- **Propane cylinders:** cylinders inside must be connected to appliance/equipment and all cylinders (full or empty) must be stored outside in a secure location.
- **Sprinkler and standpipe connections:** must be capped, free of debris and accessible.
- **Sprinkler systems:** must be inspected/tested by a qualified personnel at least once per year. Must have a current service tag (within the last 12 months) and up-to-date logbook.
- **Sprinkler valves:** must be in open position, either locked and chained or sealed and monitored electronically. No storage permitted within 18 in. of bottom of sprinkler heads.
- **Storage arrangement:** maximum height of storage of commodities must comply with the sprinkler system design.
- **Waste paper containers:** in public areas must not be combustible.

Contact:

Prince Rupert Fire Department
200 - 1st Ave. West,
Prince Rupert, B.C.
V8J 1A8

Fire Prevention
Phone: 250-627-1248
Email: fireprevention@princerupert.ca